



Comprehensive Infrastructure Agreement Amendment Approval Form

Contract Between:

Northrop Grumman Information Technology, Inc.
7575 Colshire Drive
McLean, VA 22102-7508

and

The Commonwealth of Virginia
110 South Seventh Street
Richmond, Virginia, 23219

Contract Number	VA-051114-NG
Change Control Number	Amendment No. 45
Section(s) of CIA Referenced – Identify section(s) of CIA modified, including Attachments and Schedules	CIA Schedule 4, Data Center Facility Requirements, Section 1.2.1 Hardened Site
Description of Approved Contract Change – Provide a brief description of contract change	Allow for external signage on SWESC



In accordance with Section 27.5 Amendments, and pursuant to the mutual agreement of the parties, Schedule 4 (Data Center Facilities Requirements), Section 1.2.1 (Hardened Site) of the Comprehensive Infrastructure Agreement is modified as follows:

SCHEDULE 4 TO THE COMPREHENSIVE INFRASTRUCTURE AGREEMENT
DATA CENTER FACILITIES REQUIREMENTS

1.2 Physical Site

Vendor has attached Addendum 1 to this Schedule 4, which describes more fully Vendor's solution to meet the following requirements.

1.2.1 Hardened Site

The Vendor facilities housing the VITA IT Data Center solution must meet numerous physical criteria, ranging from Tier 3 or Tier 4 standards (as defined by The Uptime Institute) to local Uniform Building Code ("UBC") seismic specifications.

The exterior walls of the facilities shall be made of double reinforced concrete and shall be anonymous, with no identifying signage outside the CESC building. The SWESC building is not limited with regard to signage. Concrete bollards or other similar barriers shall be placed around the perimeter of each facility to prevent ground-based vehicles from penetrating an exterior wall. External mechanical or equipment yards must be secured by fences and concrete bollards and must be under 24-hour motion-sensitive video surveillance.


Conduits and exterior walls must be tightly sealed to prevent moisture intrusion. Inside the facilities, flooring must be constructed with minimum live load criteria of 150 pounds per square foot ("PSF"). Cabinets or open racks must be bolted to the floor.

All terms, conditions and provisions of the original Agreement, remain unchanged except as specifically noted herein.

The parties have executed this Agreement on the dates indicated below.

Executed by:

The Commonwealth of Virginia


By: 

Name: Fred Duball

Title: SMO Director

Date: 2/1/2008

Northrop Grumman Information Technologies, Inc.

By: 

Name: James L. Dietz

Title: Senior Contracts Manager

Date: 2-1-08